




## HomeGuard - Titan Protective Housewrap

SPEC ID: 42251

HomeGuard Building Products, Inc. 5430 Shawland Road Jacksonville, FL 32254 United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



### LISTING INFORMATION

Titan Protective Housewrap is a non-perforated series of housewraps for use as an air and water barrier, and is available in two configurations: Titan Protective Housewrap HP (high permeance) (98 gsm) housewrap (60 or greater perms) and Titan Protective Housewrap LP (low permeance) (98 gsm) housewrap (15 perms).

#### **CODE COMPLIANCE RESEARCH REPORT**

| Evaluation Method              | n Method Building Code   |           |
|--------------------------------|--|-----------|
| AC38, Water-resistive Barriers | 2018, 2015 and 2012 IBC<br>2018, 2015 and 2012 IRC<br>2018, 2015 and 2012 IECC | CCRR-1092 |

#### **FLAME SPREAD RATINGS**

| Test Standard | Flame Spread | Smoke Development |
|---------------|--------------|-------------------|
| ASTM E84      | 25 or less   | 450 or less       |

| Attribute    | Value |
|--------------|-------|
| Code Reports | Yes   |

Criteria ASTM E84 (2016)
Criteria ICC-ES AC38 (2016)
CSI Code 07 27 00 Air Barriers

CSI Code 07 25 00 Weather Barriers

Intertek Services Certification

Intertek Services Code Compliance Research Report

Listed or Inspected LISTED

Listing Section EXTERIOR CLADDING SYSTEMS & COMPONENTS

Spec ID 42251



# Code Compliance Research Report CCRR-1092

Issue Date: 08-04-2017 Revision Date: 01-10-2021 Renewal Date: 01-31-2022

DIVISION: 07 00 00 – Thermal and Moisture Protection Section: 07 25 00 – Water-Resistive Barriers/Weather

**Barriers** 

Section: 07 27 00 - Air Barrier

#### REPORT HOLDER:

HomeGuard Building Products Inc. 5430 Shawland Road Jacksonville, FL 32254 (904) 240-1382

www.hgpbp.com

#### **REPORT SUBJECT:**

Titan Protective Housewrap (HP and LP), HomeGuard Housewrap (65 gsm)

#### 1.0 SCOPE OF EVALUATION

- **1.1** This Research Report addresses compliance with the following Codes:
- 2018, 2015 and 2012 International Building Code® (IBC)
- 2018. 2015 and 2012 International Residential Code® (IRC)
- 2018, 2015 and 2012 International Energy Conservation Code® (IECC)

NOTE: This report references 2018 Code sections. Earlier versions of the codes may have different section numbers.

#### 1.2 Titan Protective Housewrap:

- **1.2.1** Titan Protective Housewrap has been evaluated for the following properties (see Table 1):
- Water-resistive barrier
- Surface-burning characteristics
- Air Permeability
- **1.2.2** Titan Protective Housewrap has been evaluated for the following uses (see Table 1):
- Use as an alternative to the water-resistive barriers referenced in IBC Section 1403.2 and IRC Section 703.2

- Use as a water-resistive barrier referenced in IBC Section 2510.6 and IRC Section R703.7.3
- Use as an air barrier material under IRC Section N1102.4.1 and IECC Sections C402.5 and R402.

#### 1.3 HomeGuard Housewrap:

- **1.3.1** HomeGuard Housewrap has been evaluated for the follow property (see Table 1):
- Water-resistive barrier
- **1.3.2** HomeGuard Housewrap has been evaluated for the following uses (see Table 1):
- Use as an alternative to the water-resistive barriers referenced in IBC Section 1403.2 and IRC Section 703.2
- Use as a water-resistive barrier referenced in IBC Section 2510.6 and IRC Section R703.7.3

#### 2.0 STATEMENT OF COMPLIANCE

Titan Protective Housewrap and HomeGuard Housewrap comply with the Codes listed in Section 1.1, and for the properties and uses stated in Sections 1.2 and 1.3, when installed as described in this report, including the Conditions of Use stated in Section 6.

#### 3.0 DESCRIPTION

- **3.1 Titan Protective Housewrap:** The non-perforated housewrap is available with a basis weight of 98 grams per square meter (gsm) in two configurations, designated as HP and LP. The housewrap complies with ASTM E2556 Type II.
- **3.2** HomeGuard Housewrap: The perforated Housewrap is available with a basis weight of 65 grams per square meter (gsm). The Housewrap complies with ASTM E2556 Type I.

#### 4.0 PERFORMANCE CHARACTERISTICS

**4.1 Surface Burning Characteristics:** Titan Protective Housewrap (HP and LP) has a flame-spread index of 25 or less and a smoke-developed index of 450 when tested in accordance with ASTM E84.



ACCREDITED
Product
Certification Agency
PCA-101



**4.2 Water-vapor Permeability:** Titan Protective Housewrap HP has a permeance rating of 60 perms, and Titan Protective Housewrap LP has a permeance rating of 15 perms, when tested in accordance with ASTM E96 (Procedure A, desiccant method).

HomeGuard Housewrap has a permeance rating of 8.33 perms when tested in accordance with ASTM E96 (Procedure A, desiccant method).

- **4.3 Air Permeability:** Titan Protective Housewrap (HP and LP) has an air leakage rate not exceeding 0.02L/s/m<sup>2</sup> at 75Pa when tested in accordance with ASTM E2178.
- **4.4 Drainage Efficiency:** Titan Protective Housewrap HP has a drainage efficiency rating of 93%, when tested in accordance with ASTM E2273.

#### 5.0 INSTALLATION

- **5.1 General:** Titan Protective Housewrap and HomeGuard Housewrap must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. A copy of the manufacturer's instructions must be available on the jobsite during installation.
- **5.2 Water-resistive Barrier Application:** When used as a water-resistive barrier, Titan Protective Housewrap and HomeGuard Housewrap must be installed as described in IBC Section 1403.2 and IRC Section R703.2, and in accordance with the manufacturer's published installation instructions.

Titan Protective Housewrap may be installed as a water-resistive barrier in exterior stucco applications over wood-based sheathing in accordance with the Exception to IBC Section 2510.6 and IRC Section R703.7.3.

Homeguard Housewrap may be installed as a water-resistive barrier in exterior stucco applications over wood-based sheathing, provided two layers of the housewrap are installed in accordance with IBC Section 2510.6 and IRC Section R703.7.3.

**5.3 Air Barrier Application:** When used as an air barrier material, Titan Protective Housewrap (HP an LP) must be installed as described in IRC Section N1102.4.1, or IECC Sections C402.5 or R402.5, as applicable, and in accordance with the manufacturer's published installation instructions.

**5.4** Use on Exterior Walls of Types I, II, III, and IV Construction: Use of Titan Protective Housewrap (HP and LP) on exterior walls of Types I, II, III, and IV Construction is limited to buildings 40 feet or less in height above grade plane.

#### 6.0 CONDITIONS OF USE

- **6.1** Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict, this report governs.
- **6.2** The membranes must be covered in accordance with the manufacturer's installation instructions with an approved exterior wall covering complying with the applicable Code.
- **6.3** Titan Protective Housewrap and HomeGuard Housewrap are manufactured under a quality control program with inspections by Intertek Testing Services NA, Inc.

#### 7.0 SUPPORTING EVIDENCE

- **7.1** Reports of tests in accordance with ASTM E84, ASTM E2178, ASTM E2273, and ASTM E2556.
- **7.2** Data in accordance with the ICC-ES Acceptance Criteria for Water-resistive Barriers (AC38), approved August 2016.
- **7.3** Intertek Listing Report "HomeGuard Titan Protective Housewrap", on the Intertek Directory of Building Products.

#### 8.0 IDENTIFICATION

The Titan Protective Housewrap and HomeGuard Housewrap are identified with the manufacturer's name (HomeGuard Building Products, Inc.), address and telephone number, the product name (Titan Protective Housewrap, HomeGuard Housewrap), the Intertek Mark as shown below, and the Code Compliance Research Report number (CCRR-1092).





ACCREDITED
Product
Certification Agency
PCA-101

545 E. Algonquin Road • Arlington Heights • Illinois • 60005 intertek.com/building

Version: 6 April 2017 SFT-CCRR-OP-40b







#### 9.0 OTHER CODES

This section is not applicable.

#### 10.0 CODE COMPLIANCE RESEARCH REPORT USE

- **10.1** Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.
- **10.2** Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.
- **10.3** Reference to the <a href="https://bpdirectory.intertek.com">https://bpdirectory.intertek.com</a> is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



ACCREDITED

Product
Certification Agency
PCA-101

545 E. Algonquin Road • Arlington Heights • Illinois • 60005 intertek.com/building

Version: 6 April 2017 SFT-CCRR-OP-40b



#### **TABLE 1 - PROPERTIES EVALUATED**

| PROPERTY                                  | IBC SECTION <sup>1</sup>   | IRC SECTION <sup>1</sup>          | IECC Section <sup>1</sup>           |
|---|----------------------------|-----------------------------------|-------------------------------------|
| Water-Resistive Barrier                   | 1403.2 [1404.2],<br>2510.6 | R703.2,<br>R703.7.3<br>[R703.6.3] | NA                                  |
| Air Barrier                               | NA                         | N1102.4.1                         | C402.5 [C402.4],<br>R402.5 [R402.4] |
| Exterior Walls of Types I-IV Construction | 1403.5                     | NA                                | NA                                  |

 $<sup>^{\</sup>mathrm{1}}$  Section numbers refer to the 2018 codes with earlier code sections shown in parentheses, where different.





545 E. Algonquin Road • Arlington Heights • Illinois • 60005 intertek.com/building

Version: 6 April 2017 SFT-CCRR-OP-40b